



A Maharatna Company

एनटीपीसी लिमिटेड
(भारत सरकार का उपक्रम)
NTPC Limited
(A Govt. of India Enterprise)

रिहन्द / RIHAND

संदर्भ संख्या / Ref. no.: 070/EMG/2019

दिनांक / Date: 21.11.2019

To,
Joint Director,
Ministry of Environment, Forest & Climate Change
Regional Office (Central Region),
Kendriya Bhawan, 5th Floor, Sector-H, Aliganj,
Lucknow – 226 024.

Project Code: UP-37-302-2009
Environment Clearance letter No: J-13011/57/2008-IA-II (T) dated. 05.02.09

Sub:- Rihand Super TPP, Stage – III (2x500 MW) at Bijpur, Village, District –
Sonbhadra, Uttar Pradesh M/s NTPC Ltd.

Dear Madam,

This is with reference to your letter dated 08.11.2019 on subject matter which was received by us on 20.11.2019 through post. In this regard it is submitted that we have already sent the half yearly compliance report for the period of **October'2018 to March'2019** to your good office vide our letter dated 30.05.2019. However we are once again enclosing the copy of the same for your ready reference.

Additionally, we are also enclosing the half yearly compliance report of conditions stipulated in respect of Environmental Clearance granted for NTPC-Rihand STPP granted vide letter reference J-13011/57/2008-IA-II(T) dt. 05.02.09 for the period of **April'2019 to September'2019.**

This is for your kind information please.

Thanking You,

Yours sincerely

(V.K. Atteri)
AGM(EMG)

NTPC-RIHAND

**Status report regarding compliance of conditions stipulated in environmental clearance of
Rihand Stage-III (2x500 MW)**

Name of Project: Rihand Super thermal Power project stage III (2X500MW)

Project Code: UP-37-302-2009

Environment Clearance letter No: J-13011/57/2008-IA-II (T) dated. 05.02.09

Time Period: From: April'19 to September'2019

S. No.	Stipulation	Status of Compliance (As on 30.09.2019)
2.	It is noted that the proposal is for grant of environmental clearance for setting up of a 2x500 MW thermal power project as an expansion stage-III within the existing complex. The land requirement for the project is 730 acres, which includes 430 acres for ash disposal, 150 acres for main plant and 150 acres for railway siding and pipeline corridor. Water requirement will be met from the discharge channel of Rihand STPP Stage-I. No additional water will be drawn from Rihand Reservoir. Public hearing was held on 20.6.2008. No National Park and Wildlife Sanctuary is located within 25 Km from project area. Total cost of the project is Rs 4572.96 crores, which includes Rs. 486.50 crores for environmental protection measures.	Noted. Water requirement is being from the discharge channel of Rihand Stage -I
3.	The proposal has been considered and Ministry of Environment & Forests hereby accords environmental clearance to the said project under the provisions of Environment Impact Assessment Notification, 2006 subject to implementation of the following terms and conditions:-	Noted
(i)	No additional land shall be used/acquired in excess of 730 acres for any activity/ facility of this project.	No additional land has been used / acquired.
(ii)	Ash pond shall be at least 500 m away from FRL of Govind Ballabh Pant Sagar (Rihand Reservoir)	Shall be ensured
(iii)	Sulphur and ash contents in the coal to be used in unit-I shall not exceed 0.3% and 41%, while for unit-II, 0.38% and 37% respectively at any given time.	Sulphur content in coal was less than 0.3% during April' 2019 to September'2019. Weighted average ash content during April'19-Sept'19: 27.94%.
(iv)	A bi-flue stack of 275 m height shall be provided with continuous online monitoring equipments for SOx, NOx, Hg and Particulate. Exit velocity of flue gases shall not be less than 22 m/sec.	A bi-flue stack of 275m height has been constructed. Continuous online monitoring equipments are in service. Average exit velocity in flue gases was more than 22 m/s during the period of Apr'19 to Sept'19. .
(v)	High efficiency Electrostatic Precipitators (ESPs) shall be installed to ensure that particulate emission does not exceed 50 mg/Nm ³ .	ESPs having efficiency of more than 99.96% have been installed and commissioned to ensure that particulate emission does not exceed 50 mg/Nm ³ . PM concentration during Apr'19 to Sept'19 is enclosed as Annex.-01.
(vi)	Space provision shall be kept for retrofitting of FGD, if required at a later date.	Provision for FGD is made in General layout Plan. In order to meet the new norms of SO2 emission from the Stack the work of installation of FGD is in progress and shall be completed within the given timeline.
(vii)	Adequate dust extraction system such as cyclones/ bag filters and water spray system in dusty areas such as in coal handling and ash handling points, transfer areas and other vulnerable dusty areas shall be provided.	Dust extraction/ suppression systems have been commissioned for vulnerable dusty areas.
(viii)	Fly ash shall be collected in dry form and storage facility (silos) shall be provided. The project authorities	Dry Fly Ash Extraction, Transport, Storage and Supply system has been envisaged for

NTPC-RIHAND

	should adhere to the provision stipulated in the fly ash notification of September, 1999 and as amended in August, 2003 in regard to fly ash utilization. Unutilized fly ash and bottom ash shall be disposed off in the ash pond.	<p>Stage-III. Erection of 04 nos. of silo of capacity 1000 MT each with rail loading facility is in progress. NTPC Rihand is making best possible efforts for maximum utilization of fly ash and only unused fly ash shall be disposed off in the ash pond.</p> <p>Ash generated at NTPC Rihand is utilized in the following areas:</p> <p>a) Waste Land development b) Filling of low lying areas of plant c) Issue to cement industries d) Manufacturing of bricks e) Raising of ash dykes</p> <p>Total : 595953 MT ash utilized during (Apr'19 to Sept'19)</p>
(ix)	Closed cycle cooling system with cooling towers shall be provided. COC of at least 4 shall be adopted and the effluents shall be treated as per the prescribed norms.	Closed cycle cooling system with cooling towers has been provided in Stage III. Effluent treatment plant has also been installed in Stage - III and treated effluent is recycled and used in the power generation process. COC of 04 shall be maintained.
(x)	The treated effluents conforming to the prescribed standards shall be re-circulated and reused within the plant. Arrangements shall be made that effluents and storm water do not get mixed.	The treated effluent is being re-circulated and reused within plant. Arrangement has been made that effluent and storm water do not get mixed.
(xi)	A sewage treatment plant shall be provided and the treated sewage shall be used for raising greenbelt/plantation.	Sewage treatment plant based on MBBR technology of capacity 03 MLD and 0.5 MLD has been installed in township and plant respectively and they are in regular operation. Treated sewage water is being used in greenbelt/plantation.
(xii)	Rainwater harvesting should be adopted. Central Groundwater Authority/ Board shall be consulted for finalization of appropriate rainwater harvesting technology within a period of three months from the date of clearance and details shall be furnished.	<p>Scheme for Rainwater harvesting is envisaged in all the new buildings for Stage-III. However there is no need of rain water harvesting in flood prone area. The Rihand STPP is located in the bank of Rihand Reservoir.</p> <p>It is further submitted that 08 groundwater recharging structures of recharging capacity of approx.. 1.6 Lac cubic meter / annum.</p>
(xiii)	Adequate safety measures shall be provided in the plant area to check/ minimize spontaneous fires in coal yard, especially during summer season. Details of these measures along with location plant layout shall be submitted to the Ministry as well as to the Regional Office of the Ministry at Lucknow.	<p>Fire Fighting System and safety measures, i.e. sprinkler system, fire hydrant etc provided in stage- III package.</p> <p>Details are already submitted.</p>
(xiv)	Storage facilities for auxiliary liquid fuel such as LDO and/ HFO/L.SHS shall be made in the plant area where risk is minimum to the storage facilities. Disaster Management Plan shall be prepared to meet any eventuality in case of an accident taking place. Mock drills shall be conducted regularly and based on the same, modifications required, if any shall be incorporated in the DMP. Sulphur content in the liquid	<p>The location is Risk free. On site & off site DMP is in the place.</p> <p>Storage facility of auxiliary liquid fuels like LDO/HFO has been developed in risk free area. On site and off site Disaster Management Plan has already been prepared and implemented.</p> <p>Periodical mock drills are being conducted</p>

NTPC-RIHAND

	fuel shall not exceed 0.5%.	regularly.
(xv)	Regular monitoring of ground water in and around the ash pond area including heavy metals (Arsenic, Mercury, Cr, lead etc.) shall be carried out, records maintained and six monthly reports shall be furnished to the Regional Office of this Ministry.	Shall be complied after construction of ash dyke. However monitoring of ground water quality including heavy metals is being carried out in the surrounding areas of existing ash dykes on half yearly basis. Copies of the monitoring report is enclosed as Annexure - 01.
(xvi)	A green belt of adequate width and density shall be developed around the plant periphery covering 1/3 of project area preferably with local species.	As units under Stage-III are located within the existing premises of Stage-I and II, hence no separate green belt has been envisaged for Stage-III. Mass scale plantation and green belt development has already been undertaken in Stage-I, II, III and in township. Approx. 22.9 lac trees have been planted till Sept'19. NTPC Rihand has also entered in MoU of 10 years with U.P. Forest Department for 40000 tree plantation every year and till Sept'2019 approx. 1, 58,000 trees have been planted under MoU.
(xvii)	Adequate funds shall be allocated for undertaking CSR activities.	Sufficient funds are being allocated by NTPC Rihand for CSR activities. During Apr'19 to Sept'19 work in progress for approx. Rs. 289 Lacs (excluding community development expenses under CSR activities which shall be completed by the end of the year.
(xviii)	First aid and sanitation arrangements shall be made for the drivers and other contract workers during construction phase.	Construction of the plant is already completed. First aid centre is available in the plant.
(xix)	Noise levels emanating from turbines shall be so controlled such that the noise in the work zone shall be limited to 75 dBA. For people working in the high noise area, requisite personal protective equipment like earplugs/ear muffs etc. shall be provided. Workers engaged in noisy areas such as turbine area, air compressors etc shall be periodically examined to maintain audiometric record and for treatment for any hearing loss including shifting to non noisy/less noisy areas.	Noted and being ensured. All the persons deployed in plant area are provided with personal protective equipment like earplugs/ear muffs etc.
(xx)	Regular monitoring of the ambient air quality in the impact zone shall be carried out and records maintained. In case the air quality levels exceed the prescribed standards, necessary corrective measures shall be taken.	03 numbers of Continuous Ambient Air Quality Monitoring Station has been installed at NTPC Rihand and these are in service since the year 2010. On line data of CAAQMS is also being sent to CPCB since 28.07.2010.
(xxi)	Regular monitoring of ground level concentration of SO ₂ , NO _x , SPM and RSPM shall be carried out in the impact zone and records maintained. If at any stage these levels are found to exceed the prescribed limits, necessary control measures shall be provided immediately. The location of the monitoring stations and frequency of monitoring shall be decided in consultation with SPCB. Periodic reports shall be submitted to the Regional Office of this Ministry.	Being done. Half yearly monitoring report is enclosed as Annexure - 02.
(xxii)	A detailed plan for health monitoring in the area within the impact zone shall be prepared and implemented along with local administration. The plan should, besides others, also provide for monitoring of respiratory disorders. The plan should be submitted	Health monitoring survey was carried out by CSMMU, Lucknow. No respiratory disorders reported in conclusion of Survey report. Copy of Final Report has already been sent.

NTPC-RIHAND

	within 3 months to this Ministry and its Regional Office at Lucknow.	During April'19 to Sept'19 health check up for occupational diseases has been carried out as per following details: Employees: 315 Nos. Spouse of employee: 157 Nos. Contract workers: 5889 Nos. CISF personnel: 224 Nos.
(xxiii)	Provision shall be made for the housing of construction labour within the site with all necessary infrastructure and facilities such as fuel for cooking, mobile toilets, mobile STP, safe drinking water, medical health care, crèche etc. The housing may be in the form of temporary structures to be removed after the completion of the project.	Now the construction activity is completed and the project is in operation.
(xxiv)	The project proponent shall advertise in at least two local newspapers widely circulated in the region around the project, one of which shall be in the vernacular language of the locality concerned within seven days from the date of this clearance letter, informing that the project has been accorded environmental clearance and copies of clearance letter are available with the State Pollution Control Board/Committee and may also be seen at Website of the Ministry of Environment and Forests at http://envfor.nic.in .	Complied Advertisement issued as follows: News paper name Date of publication POINEER, 22.02.2009 LUCKNOW AMAR UJALA 23.02.2009 VARANASI
(xxv)	A separate environment management cell with qualified staff shall be set up for implementation of the stipulated environmental safeguards.	A separate environment management cell with qualified staff already exists at site.
(xxvi)	Half yearly report on the status of implementation of the stipulated conditions and environmental safeguards shall be submitted to this Ministry/ Regional Office/CPCB/SPCB.	Being complied.
(xxvii)	A) Regional Office of the MoEF located at Lucknow will monitor the implementation of the stipulated conditions. A complete set of documents including Environmental Impact Assessment Report and Environment Management Plan along with the additional information submitted from time to time shall be forwarded to the Regional Office for their use during monitoring. B) Project proponent will upload the compliance status in their website and update the same from time to time. Criteria pollutant levels (stack and ambient levels) will be displayed at the main gate of the power plant.	A) Already forwarded. B) The Data is being displayed on Main Gate
(xxviii)	Separate funds shall be allocated for implementation of environmental protection measures along with item-wise break-up. These cost shall be included as part of the project cost. The funds earmarked for the environment protection measures shall not be diverted for other purposes and year-wise expenditure should be reported to the Ministry.	Is being ensured. Expenditure of approx. Rs. 1508 lacs has been made during 2018 – 19 on environmental protection measures.
(xxix)	The project authorities shall inform the Regional Office as well as the Ministry regarding the date of financial closure and final approval of the project by the concerned authorities and the dates of start of land development work and commissioning of plant.	The unit 5th has been commercialized on 19.11.2012& unit 6th on.27.03.2014

NTPC-RIHAND

(xxx)	Full cooperation shall be extended to the Scientists/Officers from the Ministry / Regional Office of the Ministry at Lucknow /the CPCB/the SPCB who would be monitoring the compliance of environmental status.	The full co-operation is being extended to the Scientists/Officers from the Ministry / Regional Office of the Ministry at Lucknow /the CPCB/the SPCB who are monitoring the compliance of environmental status.
4.	The Ministry of Environment and Forests reserves the right to revoke the clearance if conditions stipulated are not implemented to the satisfaction of the Ministry. MOEF may impose additional environmental conditions or modify the existing ones, if necessary.	Noted.
5.	The environmental clearance accorded shall be valid for a period of 5 years to start operations by the power plant.	Noted.
6.	In case of any deviation or alteration in the project proposed including coal transportation system from those submitted to this Ministry for clearance, a fresh reference should be made to the Ministry to assess the adequacy of the condition(s) imposed and to add additional environmental protection measures required, if any.	Noted.
7.	The above stipulations would be enforced among others under the Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986 and rules there under, Hazardous Wastes (Management and Handling) Rules, 1989 and its amendments, the Public Liability Insurance Act, 1991 and its amendments.	Noted.
8.	Any appeal against this environmental clearance shall lie with the National Environment Appellate Authority, if preferred, within 30 days as prescribed under Section 11 of the National Environment Appellate Act, 1997.	Noted.



सीएसआईआर-भारतीय विषविज्ञान अनुसंधान संस्थान
CSIR-INDIAN INSTITUTE OF TOXICOLOGY RESEARCH



वैज्ञानिक तथा औद्योगिक अनुसंधान परिषद्
COUNCIL OF SCIENTIFIC & INDUSTRIAL RESEARCH

Ref. IITR/NTPC-Rh./ June -V/19
July 22, 2019

Phase-V Study
Analytical Results of Ground Water Samples

Source of Sample : Ground Water Samples (Well and Hand Pump)
Site : Rihand Super Thermal Power Station, NTPC, Rihandnagar
Date of Sampling : June,29,2019 , **Season and Weather** : Summer Season and Clear Day

SL	PARAMETERS	Unit	Iron Colony (Well Water) [GWQ*-I]	Central Ash Dyke (Well Water) [GWQ-II]	Sirsoti Hand Pump [GWQ-III]	Punarwas-1 Hand Pump [GWQ-IV]	Punarwas-2 Hand Pump [GWQ-V]	Acceptable Limit***
1.	Fluoride (as F ⁻)	mg/l	0.64	0.41	0.86	0.96	0.89	1.0
2.	Cadmium (as Cd)	mg/l	BDL*	BDL	BDL	BDL	BDL	0.003
3.	Tot. chromium (as Cr)	mg/l	BDL	BDL	BDL	BDL	BDL	0.05
4.	Copper (as Cu)	mg/l	0.032	0.039	0.037	0.024	0.046	0.05
5.	Lead (as Pb)	mg/l	BDL	BDL	BDL	BDL	BDL	0.01
6.	Iron (As Fe)	mg/l	0.084	0.256	0.147	0.087	0.093	0.3
7.	Zinc (as Zn)	mg/l	0.166	1.19	0.122	0.091	0.089	5.0
8.	Selenium (as Se)	mg/l	BDL	BDL	BDL	BDL	BDL	0.01
9.	Arsenic (as As)	mg/l	BDL	BDL	BDL	BDL	BDL	0.01
10.	Mercury (as Hg)	mg/l	BDL	BDL	BDL	BDL	BDL	0.001

GWQ*..... Ground Water Quality
Remarks: On comparing the analytical results with prescribed standards for drinking water; IS : 10500; the analysed parameters were found within their respective permissible limits.
BDL* Below Detection Limit
***BUREAU OF INDIAN STANDARDS: DRINKING WATER – SPECIFICATION (Second Revision of IS- 10500)
ICS No. 13.060.20

(Signature)
(G. C. Kisku)

विषविज्ञान भवन, 31, महात्मा गाँधी मार्ग
पोस्ट बाक्स नं० 80, लखनऊ, उ.प्र., भारत
VISHVIGYAN BHAWAN, 31, MAHATMA GANDHI MARG
POST BOX NO 80, LUCKNOW-226001, U.P. INDIA

Phone: +91-522-2627586, 2614118, 2628228 Fax: +91-522-2628227, 2611547
director@iitrindia.org www.iitrindia.org



STATION :- NTPC- RIHAND
 PERIOD :- 26th March, 2019 to 25th September 2019
 AMBIENT AIR QUALITY DATA

MONTH	Awantika			Bijpur Purnavas			MGR			Shiv Mandir (PTS)					
	DATE	PM 2.5	PM 10	SOx	NOx	DATE	PM 2.5	PM 10	SOx	NOx	DATE	PM 2.5	PM 10	SOx	NOx
April 19	27.03.19	47	68	12	23	29.03.19	48	94	16	28	30.03.19	36	59	10	37
	03.04.19	52	83	16	19	05.04.19	57	79	14	19	06.04.19	44	78	11	39
	10.04.19	42	78	13	22	12.04.19	53	79	13	19	13.04.19	56	83	11	52
	17.04.19	50	82	13	26	19.04.19	32	38	13	20	20.04.19	28	76	11	48
May 19	01.05.19	41	77	12	26	26.04.19	49	79	13	19	27.04.19	50	83	11	59
	08.05.19	47	64	11	24	03.05.19	21	27	13	19	04.05.19	30	64	11	53
	15.05.19	40	82	14	28	10.05.19	29	57	13	19	11.05.19	50	77	12	19
	22.05.19	59	84	12	21	17.05.19	49	76	14	19	18.05.19	54	72	13	16
June 19	29.05.19	55	84	11	21	31.05.19	35	46	12	18	01.06.19	52	84	11	18
	05.06.19	46	89	12	19	07.06.19	36	40	14	22	08.06.19	46	78	14	19
	12.06.19	51	74	14	18	14.06.19	25	68	14	22	15.06.19	48	80	13	25
	19.06.19	53	92	10	17	21.06.19	32	65	14	22	22.06.19	44	74	13	27
July 19	26.06.19	44	72	16	24	28.06.19	21	42	14	23	29.06.19	26	57	13	21
	03.07.19	27	58	12	24	05.07.19	10	15	14	24	06.07.19	12	21	13	17
	10.07.19	21	37	15	20	12.07.19	26	52	14	25	13.07.19	20	57	13	18
	17.07.19	24	31	11	22	19.07.19	27	51	13	25	20.07.19	18	40	14	31
Aug. 19	31.07.19	37	62	12	18	26.07.19	13	16	15	23	27.07.19	18	33	14	20
	07.08.19	24	44	12	15	02.08.19	20	24	15	24	03.08.19	16	30	14	25
	14.08.19	28	51	10	17	09.08.19	13	15	14	40	10.08.19	12	32	14	29
	21.08.19	19	37	12	18	16.08.19	15	27	13	45	17.08.19	12	27	15	30
Sept. 19	28.08.19	35	65	12	18	30.08.19	14	22	14	18	31.08.19	15	31	15	27
	04.09.19	31	57	16	24	06.09.19	15	21	14	32	07.09.19	27	50	15	27
	11.09.19	35	65	11	17	13.09.19	9	12	15	29	14.09.19	17	31	16	33
	18.09.19	35	69	15	21	20.09.19	12	18	16	29	21.09.19	27	40	16	44

NTPC RIHAND
STACK MONITORING REPORT (Apr'19 - Sept'19)
STAGE - III

Limit for PM: 50 mg/Nm3

	Unit # 5			Unit # 6		
	PM (mg/Nm3)	SO2 (mg/Nm3)	Nox mg/Nm3	PM (mg/Nm3)	SO2 (mg/Nm3)	Nox mg/Nm3
Apr'19	44.75	518.25	361	44.75	506.5	335.5
May'19	45	477	355.5	42.5	456.5	317.25
June'19	48	575	354	47	535	325
July'19	45	581	340	45	570	332
Aug'19	44	572	372	44	577	371
Sept'19	46	493	332	44	483	343
AVG.	45.46	536.04	352.42	44.54	521.33	337.29