



NTPC/KGN/EMG/EC-MOEF/2020

Date: 24.04.2020

To

**The Additional Principal Chief Conservator of Forests (C),
Ministry of Environment, Forest and Climate Change,
Regional Office (WZ),
Kendriya Paryavaran Bhawan,
E-5 Arera Colony, Link Road-3,
Ravishankar Nagar,
Bhopal-462016, Madhya Pradesh**

**Sub: Submission of 10th Half Yearly Environmental Clearance Compliance Report of
Khargone Super Thermal Power Project (2 x660 MW) at Village Selda & Dalchi,
Khargone, Madhya Pradesh by NTPC Ltd.**


EC Ref: J-13012/54/2010-1A.II (T), Dated-31.03.2015

Sir,

With reference to the above mentioned subject we are submitting the half yearly compliance report to stipulated conditions of Environmental Clearance in soft (email id- rowz.bpl-mef@nic.in) & hard copy for the period (Oct'2019 - Mar'2020) for your kind records please.

Thanking you,

Yours sincerely,


(A K Goswami)

**Chief General Manager
Khargone Super Thermal Power Project**

Encl. as above

Copy to:

1. The Director
IA Division
Ministry of Environment, Forest and Climate Change,
Paryavaran Bhawan,
Lodhi Road, New Delhi-110003
2. The Chairman,
Central Pollution Control Board,
Parivesh Bhawan, CBD- cum-Office Complex,
East Arjun Nagar, **Delhi-110032**
3. The Chairman,
Madhya Pradesh Pollution Control Board,
Parivesh Bhawan, E-5 Arera Colony,
Paryavaran Parisar, **Bhopal-462016**

KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i>		
	MOEF & CC Stipulations	NTPC Response
A	Specific Conditions:	Status as on 31.03.2020
i	Coal transportation shall be by Rail only. An additional EIA shall be carried out and an EMP shall be prepared for laying down the rail line and alternate mode of transportation, in case rail line gets delayed. The EIA/EMP shall be submitted to the Ministry within one year of issuing the EC.	Presently the rail network for Khargone project has been established and entire coal is being transported by railway route only. However, earlier MOEF&CC vide letter dated 22.08.2019 accorded the EC amendment for transportation of 2,000 Tons/day of coal from NEPA Railway siding to Khargone plant premises for a temporary period of one year.
ii	The Sulphur and Ash content of coal shall not exceed 0.5% and 43% respectively. In case of variation of quality at any point of time, fresh reference shall be made to the Ministry for suitable amendments in the environmental clearance.	The said stipulation is being complied. However, NTPC shall approach MOEF&CC for suitable amendments in the environmental clearance in case of any variation in coal quality.
iii	Latest authenticated satellite imagery shall be submitted to the Regional Office of the Ministry on an annual basis to monitor the environmental alterations of the area.	Land use classification based on latest satellite imagery shall be submitted to the Regional Office (Western Zone) of the MOEF&CC at Bhopal on an annual basis.
iv	Vision document specifying prospective plan for the site shall be formulated and submitted to the Regional Office of the Ministry within six months.	Vision document specifying prospective plan of the project was submitted to the Regional Office (Western Zone) of the MOEF&CC at Bhopal vide NTPC letter dated 07.09.2015.
v	Harnessing solar power within the premises of the plant particularly at available roof tops shall be carried out and status of implementation including actual generation of solar power shall be submitted along with half yearly monitoring report.	NTPC vide letter dated 07.09.2015 has submitted Scheme for harnessing solar power by installation of roof top solar plant within the premises of the Khargone project. For the implementation of scheme, Contract for installation of Roof-top Solar power plant has been already awarded to M/s Waree by main EPC contractor M/s L&T in 2019. Submission & approval of document is in process. Supply expected in 10-12 weeks after approval of documents. Installation shall be done by readiness of buildings (Workshop, Stores & Canteen)
vi	One twin flue stack of 275 m height shall be provided with continuous on-line monitoring system of SO _x , NO _x and PM _{2.5} & PM ₁₀ . Exit velocity of flue gases shall not	<ul style="list-style-type: none"> • A twin-flue stack of 275-meter height has been provided. • Continuous online emission monitoring system (CEMS) facilities are provided for

<p align="center">KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i></p>		
	<p>be less than 22 m/sec. In addition to the regular parameters, Mercury emission form stack shall also be monitored of six monthly basis.</p>	<p>monitoring of SO₂, NO_x and Particulate matter (PM).</p> <ul style="list-style-type: none"> Exit velocity of flue gases being maintained less than 22 m/sec. Mercury emission form stack shall also be monitored on six monthly basis.
vii	<p>High Efficiency Electrostatic Precipitators (ESPs) shall be installed to ensure that particulate emission does not exceed 50 mg/Nm³. Adequate dust extraction system such as cyclones/bag filters and water spray system to control fugitive emissions in dusty areas such as in coal handling and ash handling points, transfer areas and other vulnerable dusty areas shall be provided.</p>	<p>The High Efficiency Electrostatic Precipitators (ESP) is designed for a guaranteed efficiency of 99.97%. The particulate emission will be controlled and maintained below 30 mg/Nm³ in compliance to latest MOEF&CC emission norms for TPP dated 07.12.2015.</p> <p>Adequate dust extraction system and water spray system are provided to control fugitive emissions at coal handling, coal stockyard and ash handling area, transfer points and other vulnerable dusty areas.</p>
viii	<p>COC of at least 5.0 shall be adopted.</p>	<p>Closed cycle cooling water re-circulation system has been designed and implemented with minimum Cycle of Concentration (COC) of 5.0 for conservation/optimization of water requirement for the project.</p>
ix	<p>Monitoring of surface water quantity and quality shall be conducted regularly and records shall be maintained. The monitoring points shall be located between the plant and drainage in the direction of flow of ground water and records shall be maintained. The monitored data shall be submitted to the Ministry every six months.</p>	<p>Monitoring of Surface water quality as per stipulations is being carried out regularly through Regional Laboratory, MPPCB and reports are submitted to Regional Office (Western Zone) of the MOEF&CC at Bhopal at every six monthly.</p> <p>Pl. ref. reports enclosed at Annexure-I.</p>
x	<p>Monitoring for heavy metals in ground water in the vicinity of plant shall also be undertaken and monitoring report shall be submitted to the ministry every six months.</p>	<p>Regular monitoring of heavy metals in ground water in and around plant area being carried out regularly through Regional Laboratory, MPPCB as per stipulation and report submitted to Regional Office (Western Zone) of the MOEF&CC at Bhopal every six monthly</p> <p>Pl. ref. reports enclosed at Annexure-I.</p>
xi	<p>A well designed rain water harvesting system shall be put in place within six months, which shall comprise of rain water collection from the built up and open area in the plant premises and</p>	<p>Detailed rainwater harvesting study has been already carried out at the project through M/s RAJMI Geo-exploration & Engineering Pvt. Ltd, Indore.</p>

KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i>	
	<p>records shall be kept for the quantity of water harvested every year and its use.</p> <p>A well-designed rainwater harvesting system shall be established as per recommendations of study report and relevant stipulations. Records shall be maintained for the quantity of water harvested every year and its use.</p> <p>Presently, approval of Rain water harvesting scheme is obtained from CGWA, Bhopal. Implementation of RWHS in progress.</p>
xii	<p>No water bodies including natural drainage system in the area shall be disturbed due to activities associated with the setting up/ operation of the power plant.</p> <p>No water body including natural drainage system of the area has been disturbed due to activities associated with the setting up of the power plant and during the operation of the project.</p>
xiii	<p>Hydro geology of the area shall be reviewed annually through an institute/ organization of repute to assess impact of surface water and ground water (especially around ash dyke). In case, any deterioration is observed specific mitigation measures shall be undertaken immediately. Reports/ data of water quality shall be submitted to the Regional Office of the Ministry every six months.</p> <ul style="list-style-type: none"> • The baseline Hydro-geological study at Khargone project has been carried out through National Institute of Hydrology (NIH), Roorkee and its study report has already been submitted along with 8th HYC report dated 22.04.2019. • Further, the study will be reviewed annually from an institute/ organization of repute to assess impact of surface water and ground regime (especially around ash dyke) and reports of water quality monitored will be submitted every six monthly to the Regional Office (Western Zone) of the MOEF&CC at Bhopal.
xiv	<p>Waste water generated from the plant shall be treated before discharge to comply with the standards prescribed by the SPCB/CPCB.</p> <p>An Effluent Management Scheme has been designed and is being implemented with the objective to treat the entire waste water as per the prescribed statutory standards of MPPCB/CPCB before its discharge.</p> <p>It is to be submitted that during normal course of project operation the feasibility of zero discharge shall be adopted based on maximum recycle/reuse of waste water for various plant usage thereby reducing and optimizing the quantities of water requirement and effluent generation to the extent feasible.</p>

KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i>		
xv	Additional soil for leveling of the proposed site, if require shall be taken from within the sites (to the extent possible) so that natural drainage system of the area is protected.	All additional soil leveling of the project site being taken from within the sites only (to the extent possible) with all necessary precautions to protect natural drainage system of the area.
xvi	Fly ash shall be collected in dry from and storage facility (silos) shall be provided. Un-utilized fly ash shall be disposed off in the ash pond in the form of slurry. Mercury and other heavy metals (As, Hg, Cr, Pb etc.) will be monitored in the effluents emanating from the ash pond and in the bottom ash also. No ash shall be disposed off in low lying area.	<p>An ash management & disposal scheme being implemented consisting of dry ash extraction system (DAES) for dry collection of fly ash with adequate storage facility (silos), supply of ash to entrepreneurs for utilization and promoting ash utilization to maximum extent and safe disposal of un-utilized ash in the ash pond in the form of slurry.</p> <p>A long term agreement for fly ash utilization of about 3055 MT/day has been already done with cement industries. Copy of MOUs already submitted along with 9th HYC report on 02/11/19.</p> <p>Two different systems are being provided for ash disposal- Conventional wet slurry disposal system with ash water re-circulation for bottom ash and High Concentration Slurry Disposal (HCSD) system for fly ash.</p> <p>Periodic monitoring for mercury & heavy metals in the bottom ash and water emanating from ash pond will also be carried out.</p>
xvii	Fugitive emission of fly ash (dry or wet) shall be controlled such that no agricultural or non-agricultural land is affected. Damage to any land shall be mitigated and suitable compensation shall be provided in consultation with the local Panchayat.	<p>Fugitive emission of fly ash & dust being controlled up to the maximum extent with the aid of suitable pollution control devices such as ESP, Dust Extraction, Dust Suppression systems and water spray arrangements etc.</p> <p>Further, extensive plantation being undertaken in all available spaces including ash & coal handling areas, ash pond area etc. selectively with Air Pollution Tolerant (APTI) plant species.</p> <p>Ash being disposed off in the designated area only. Moreover, trucks with closed containers/bulker being used for transportation of fly ash in order to avoid any dust emission.</p>

**KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW)
COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS**

(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)

xviii	Ash pond shall be lined with HDPE/LDPE lining or any other suitable impermeable media so that no leaching takes place at any point of time. Adequate safety measures shall also be implemented to protect the ash dyke from getting breached.	<p>To avoid any leaching and ground water contamination from ash slurry, bottom ash lagoons are being provided with impervious lining with suitable impermeable material i.e. Bentonite blended clay in order to achieve the required permeability.</p> <p>Over flow lagoon of ash dyke is also designed with and lined with impervious thick liner of 300 MM at bottom.</p> <p>The structure of ash dykes has been designed, constructed and will be operated as per State of the Art engineering practices for the design and construction of earth dams with adequate factor of Safety. The ash dyke is being constructed considering the seismic parameters in its design.</p>
		Regular monitoring and inspection of ash dykes and an emergency response system will ensure that there are no risks of failure as apprehended.
xix	A long term study of radioactivity and heavy metals contents of coal to be used shall be carried out through a reputed institute and results shall be analyzed every two years and shall be reported to the Ministry along with the monitoring reports. Thereafter, mechanism for an in-built continuous monitoring for radioactivity and heavy metals in coal and fly ash (including bottom ash) shall be put in place.	<p>A detailed study on heavy metals contents of coal being used and radioactivity contents has been carried out through M/s Cotecna Inspection India Pvt. Ltd., Indore and Department of Atomic Energy, Board of Radiation & Isotope Technology, Navi Mumbai respectively. The copy of report are enclosed at Annexure-II & III respectively.</p> <p>Further long-term study on heavy metal and radioactivity contents will continued to be carried out through a reputed institute.</p>
xx	Green Belt of least 50m width consisting of three tiers of plantations of native species around the plant shall be raised. Wherever 50m width is not feasible, an adequate justification shall be submitted to the Ministry and appropriate width not less than 20m shall be planted. Tree	<p>Around 124 acres of land has been envisaged for the green belt development.</p> <p>Green Belt around the Main Plant area except transmission corridor is being planted.</p> <p>Green Belt around the Township area also being planted.</p>

**KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW)
COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS**

(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)

	<p>density shall not be less than 2500 per ha with survival rate not less than 80%.</p>	<p>Extensive afforestation will be undertaken at all available spaces in and around project, after construction is complete.</p> <p>Avenue Plantation along the Road also being done.</p> <p>Shelter belt Plantations along the vicinity of ash storage/ disposal sites/ water reservoirs and along boundary walls is being taken up.</p> <p>About 31,200 saplings has been planted till date under green belt development in and around NTPC premises.</p> <p>Further, about 2,00,000 saplings have been planted outside the plant premises at various locations in Dist. Khandwa, Khargone at MP Rajya Van Vikas Nigam Limited's sites under the additional carbon sink plantation. Plantation of 50,000 saplings done under carbon sink scheme in FY 2019-20. Plantation of 5,000 saplings done at roadside of Katora-Selda road in FY 2019-20.</p> <p>Also, about 5,000 fruit plant saplings distributed among local villagers.</p>
		<p>Plantation of about 10,000 saplings planned in FY-2020-21 under greenbelt and about 50,000 is planned under Carbon sink scheme of NTPC ltd.</p>
xxi	<p>Green belt shall also be developed around the Ash Pond over and above the Green Belt around the plant boundary.</p>	<p>Green belt being developed around the plant boundary. Further plantation shall also be done around ash pond.</p>
xxii	<p>CSR schemes identified based on need based assessment shall be implemented in consultation with the village Panchayat and the District Administration starting from the development of project itself. As part of CSR, prior identification of local employable youth the eventual employment in the project after imparting relevant training shall be also undertaken. Company shall provide separate budget for community</p>	<p>Various CSR/CER/R&R initiatives and schemes are being implemented based on need based survey in consultation with the village Panchayat and the District Administration.</p> <p>Infrastructural development: Construction of Internal roads, Culverts, Bus stand, Community centers, Solar street lights, Bridges and Drains are being provided in nearby villages.</p>

**KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW)
COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS**

(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)

<p>development activities and income generation programs.</p>	<p>Drinking Water: Renovation/Up-gradation & Providing of of water pipelines, Construction of water tank, Sump pit, Development of water source and Construction of Ghats are being provided in nearby villages.</p>
	<p>Education: Construction of additional class rooms Boundary wall & Renovation of school, Distribution of desk, bench, chair, table, school uniforms & sports materials, fencing of ground, Rural sports camps, Distribution of scholarships etc. are being provided.</p>
	<p>Health: Medical camps, Eye checkup & Dental checkup and Hygiene medical camps are being organized, provided air conditioners to Govt. hospitals, Hiring/deployment of Mobile health clinic are being provided.</p>
	<p>Training: Training to physically challenged person & distribution of Aid Equipment's, distribution of tricycles. Training for General Electrician & Domestic wiring, Car driving, Distribution of sewing machines, tool kits for electricians. Training for Computer education, Beautician, Dress making, Masala papad making, Manufacturing of cattle feed are being provided for women empowerment.</p>
	<p>Worship Site: Repairing /Renovation of Mandir at Maheshwar</p>
	<p>Cultural activities/Music & Festivals: Financial aids provided to nearby villages for cultural events, Public address system, tents & chairs are being provided for cultural & spiritual events.</p>
	<p>Adm. Recommendation Works: Construction of toilets, Distribution of computers, printers, Fin. aid for CCTV cameras, Construction of community centers, boundary wall, renovation of temples, Fin. aid for Collector-Nirashrit Nidhi Yojna, Construction of Goumukh Ghat, Safety Wall</p>

<p align="center">KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i></p>		
		<p>from Narmda River to back side of Temple, Solar light etc are being done.</p> <p>Apart from the above various infrastructure development (i.e. community center, boundary wall, road, school bhawan, solar lights, construction of ghats, drainage, water pipelines, panchayat bhawan) and other community works are also being taken up in the villages affected by Railway siding.</p> <p>The total R&R budget is Rs. 3199 + 720 = Rs. 3919 Lakhs, wherein the total R&R expenditure incurred is Rs.1356,64 + 517.79= Rs.1874.43 Lakhs including the expenditure incurred for financial year 2019-20 i.e. Rs.594.27+ 303.29 = Rs. 897.56 Lakhs.</p>
xxiii	For periodic monitoring of CSR activities, a CSR Committee or a Social Audit committee or a suitable credible external agency shall be appointed. CSR activities shall also be evaluated by an independent external agency. This evaluation shall be both concurrent (every six months) and final.	Periodic monitoring of CSR activities, Need Assessment Survey and Social Audit for community development program for Khargone STPP will be done through from the suitable credible external agency or reputed Government institute in the region.
xxiv	An Environmental Cell comprising of at least one expert in environmental science/ engineering, ecology, occupational health and social science shall be created preferably at the project site itself and shall be headed by an officer of appropriated seniority and qualification. It shall be ensured that the Head of the cell shall directly report to the Head of the Plant who would be accountable for implementation of environmental regulations and social impact improvement/mitigation measures.	<p>An Environment Management Group (EMG) with qualified team headed by AGM (Chem. & EMG) is already functional at the Khargone project site.</p> <p>EMG is responsible for implementation and compliance of environmental stipulations. EMG is having sufficient qualified/trained manpower for environmental management to ensure implementation of environmental regulations and social impact improvement/mitigation measures.</p>
B	General Conditions:	
i	Space for FGD shall be provided for future installation, if required.	<p>Adequate space has been provided in the layout for installation of FGD plant.</p> <p>Installation of FGD plant package awarded to M/s L&T in Sep'2018.</p> <p>Erection works are in full swing and Expected to be completed within 34 months.</p>

**KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW)
COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS**

(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)

ii	<p>The treated effluents conforming to the prescribed standards under Environment (Protection) Act 1986 only shall be re-circulated and reused within the plant. Arrangements shall be made that effluents and storm water do not get mixed.</p>	<p>Effluent treatment system comprising of ETP, neutralization pit, oil and grease separator, lamella clarifier, cooling towers etc. are being provided. The effluents being treated adequately conforming to the prescribed regulatory standards.</p> <p>The project shall have an integrated scheme for treatment, re-cycle and re use of effluents. Provision being kept to re-circulate cooling water and ash pond effluent. The entire cooling tower blow down being reused in CHP, AHP and firefighting.</p> <p>An independent plant effluent drainage system is being constructed to ensure that plant effluents do not mix with storm water drainage.</p> <p>Further, Zero Liquid Discharge (ZLD) scheme is being implemented for recycle & reuse of waste water generated, thereby reducing and optimizing the quantities of water requirement and effluent generation to the extent feasible.</p>
iii	<p>A sewage treatment plant shall be provided (as applicable) and the treated sewage shall be used for raising greenbelt/plantation.</p>	<p>Sewage treatment plant is being provided to treat All domestic sewage emanating from plant and township.</p> <p>The treated sewage, conforming to prescribed standards shall be utilized for plantation & raising greenbelt to the extent possible.</p>
iv	<p>Adequate safety measures shall be provided in the plant area to check / minimize spontaneous fires in coal yard, especially during summer season. Copy of these measures with full details along with location, plant layout etc. as and when finalized, shall be submitted to the ministry as well as to the regional office of the Ministry.</p>	<p>Adequate no. of fire Spray & Hydrant system covering the entire power station including all the auxiliaries and buildings in the plant area being provided as per fire safety requirements. The system is adequately equipped with piping, hydrants, valves, instrumentation, hoses, nozzles, hose boxes/stations etc.</p> <p>Copy of safety measures details are already submitted along with 8th HYC report dated 22.04.2019.</p>

**KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW)
COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS**

(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)

v	<p>Separate storage facilities for auxiliary liquid fuel such as LDO/HFO/LSHS shall be made in the plant area in consultation with Department of Explosives, Nagpur. Sulphur content in the liquid fuel will not exceed 0.5%. Provisions of the Manufacture, Storage and Import of Hazardous Chemical Rules and the Chemical Accidents (Emergency Planning, Preparedness and Response) Rules, 1996 shall be applicable as per the quantity stored. Disaster Management System shall be established as per the Disaster Management Plan to meet any eventuality in case of an accident taking place due to storage of oil.</p>	<p>Storage facility is designed and provided for LDO as auxiliary liquid fuel, inside plant area conforming to the adequate safety standard and where risk is minimal. Necessary license has been obtained from Department of Explosives, Nagpur.</p> <p>Sulphur content in LDO is being ensured within limits.</p> <p>A detailed Disaster Management Plan & Risk assessment including fire and explosion issues is being prepared and finalized in consultation with Department of Explosives, Nagpur. Regular mock drills being conducted as per plan in order to address any eventuality in case of an accident.</p>
vi	<p>First Aid and sanitation arrangements shall be made for the drivers and other contract workers during construction phase.</p>	<p>All arrangements related to first aid, health & safety and sanitation for workers during construction phase of the project have been kept under the scope of EPC contractor. However, NTPC being ensuring effective compliance of the said stipulations.</p> <p>Various measures implemented during construction phase through contractor are:-</p> <ul style="list-style-type: none"> • Adequate infrastructure facilities, such as sanitation, fuel, restroom, medical facilities, safety, and suitable water supply being provided at various stages of project construction to the labor colonies housing the work force during construction phase of the project. • Safety equipment such as earplugs and earmuffs, helmets, face shields, safety goggles etc. being provided to workers engaged in high risk areas. • A first aid center facility has been provided in township as well as plant area to provide immediate medical aid to the workers and their family members.

<p align="center">KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i></p>		
		<ul style="list-style-type: none"> • 24x7 hrs. ambulance service is available at site to transport injured workers to nearby hospitals.
vii	Noise levels from turbines in work zone shall be limited to 85 dB (A) from source. For people working in the high noise area, requisite personal protective equipment like earplugs/ear muffs etc. shall be provided. Workers engaged in noisy areas such as turbine area, air compressors etc. shall be periodically examined to maintain audiometric record and for treatment for any hearing loss including shifting to non-noisy/less noisy areas.	<p>Design specification for the equipment's has been made to comply with the stipulation. Requisite personal protective equipment's (PPE's) has been provided through contractors during construction phase. Periodic examination of workers also being done as stipulated.</p> <p>Workers of generator hall and other high noise area are being provided with appropriate ear protection devices/PPEs.</p>
viii	Regular monitoring of ambient air ground level concentration of SO ₂ , NO _x , PM _{2.5} & PM ₁₀ and Hg shall be carried out in the impact zone of the project and record shall be maintained. In case these levels exceed the prescribed limits, necessary control measures shall be taken immediately. The location of the monitoring stations and frequency of monitoring shall be decided in consultation with SPCB. Monitoring reports shall be submitted to the Regional Office of this Ministry every six months. The data shall also be uploaded on the website of the company.	<p>Regular monitoring of ambient air quality being carried out regularly through Regional Laboratory, MPPCB and reports are submitted at every six months. Ambient air quality reports enclosed at Annexure-I</p> <p>Further, three nos. of continuous AAQMS stations has been also installed and commissioned at main plant and township. One more AAQMS stations at Khargone city shall be installed. The locations of monitoring stations have been finalized in consultation with MPPCB.</p> <p>The ambient air monitoring data being uploaded on intranet website of the company.</p>
ix	Fly Ash generated shall be utilized 100% from the 4 th year of operation of the power plant. Status of fly ash utilization shall be reported each year to the Regional Office of the Ministry.	Ash utilization plan has been prepared and shall be implemented in compliance to fly ash gazette notification dated 03.11.2009 and its amendments thereafter. Status of fly ash utilization shall be reported each year to the regional office (Western Zone) of MOEF&CC at Bhopal.
x	Provision shall be made for the housing of construction labor (as applicable) within the site with all necessary infrastructures and facilities such as fuel for cooking, mobile toilets, mobile STP, safe drinking water, medical health care, crèche etc.	Labor colony with necessary infrastructure facilities such as housing, sanitation, mobile toilet, fuel, medical facilities, safety, drinking water supply etc. has been provided for construction labor.

KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i>		
	<p>The housing may be in the form of temporary structure to be removed after the completion of the project.</p>	<p>The same has been kept have been kept under the scope of EPC contractor. However, NTPC ensures effective compliance of the said stipulations.</p>
xi	<p>The project proponent shall advertise in at least two local newspapers widely circulated in the region around the project, one of which shall be in the vernacular language of the locality concerned within seven days from the date of receipt of this clearance letter, informing that the project has been accorded environmental clearance and copies of clearance letter are available with the State Pollution Control Board/Committee and may also be see at Website of the Ministry of Environment and Forests at http://envfor.nic.in.</p>	<p>The information of Environmental Clearance was published in two newspapers widely circulated in the region;</p> <ol style="list-style-type: none"> 1. Hindustan Times (English) on dated 04.04.2015. and 2. Nai-Dunia (Hindi) on dated 04.04.2015.
xii	<p>A copy of the clearance letter shall be sent by the proponent to concerned Panchayat, Zila parisad/ Municipal Corporation, urban local body and the Local NGO, if any, from whom suggestions/representations, if any, received while processing the proposal. The clearance letter shall also be put on the website of the Company by the proponent.</p>	<p>Copy of clearance letter were sent vide our letter dated 06.04.2015 to Sarpanch of village Panchayat of Selda & Dalchi village, CEO of Khargone Distt & CEO of Khargone Municipal Corporation.</p> <p>The Environmental Clearance is uploaded on the NTPC website.</p>
xiii	<p>The proponent shall upload the status of compliance of the stipulated environmental clearance conditions, including results of monitored data on their website and shall update the same every six months. It shall simultaneously be sent to the Regional Office of MOEF, the respective Zonal Office of CPCB and the SPCB.</p>	<p>The latest status of Half Yearly Compliance (HYC) report of EC conditions is regularly being submitted to the Regional Office (Western Zone) of the MOEF&CC at Bhopal and offices of CPCB & MPPCB. Latest compliance status of EC being also uploaded on the NTPC website, which is periodically being replaced with updated HYC report.</p>
v	<p>The criteria pollutant levels namely; SPM, RSPM (PM_{2.5} & PM₁₀), SO₂, NO_x (ambient levels as well as stack emissions) shall be displayed at a convenient location near the main gate of the company in the public domain.</p>	<p>Online Continuous Emission Monitoring System (CEMS) for Stack emission, to monitor pollutant parameters namely; Particulate Matter (PM), NOX, & SO₂ has been provided.</p> <p>For regular monitoring of ambient air quality, three nos. of CAAQMS has been installed at main plant and township. Further one more</p>

KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i>	
	<p>station is being provided at Khargone city as per MPPCB directions.</p> <p>Relevant environment data for pollutant levels along with Hazardous wastes & Haz. chemicals handled, being displayed at a convenient location near the main gate of the company in the public domain.</p>
xv	<p>The environment statement for each financial year ending 31st March in Form-V as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently, shall be submitted by the project proponent to the concerned State Pollution Control Board. The same shall also be uploaded on the website of the company along with the status of compliance of environmental clearance conditions and shall also be sent to the respective Regional Offices of the Ministry by e-mail.</p> <p>The Environment Statement for each financial year ending 31st March in Form-V shall be submitted by Jun'20 to the MPPCB & Regional Office (Western Zone) of the MOEF&CC at Bhopal.</p>
xvi	<p>The project proponent shall submit six monthly reports on the status of the implementations of the stipulated environmental safeguards to the Ministry of Environment and Forests, its Regional Office, Central Pollution Control Board and State Pollution Control Board. The project proponent shall upload the status of compliance of the environment of the environmental clearance conditions on their website and update the same every six months and simultaneously send the same by email to the Regional office, Ministry of Environment and Forests.</p> <p>Six monthly compliance status report of EC conditions is regularly being submitted to the Regional Office of MOEF&CC, CPCB & MPPCB and being uploaded on the NTPC website, which is periodically being replaced with updated report.</p> <p>The latest half yearly progress report for the period of October'2019 to March'2020 is being submitted herewith.</p>
xvii	<p>Regional office of the Ministry of Environment & Forests will monitor the implementation of the stipulated conditions. A complete set of documents including Environmental Impact Assessment Report and Environment Management plan along with the additional information submitted from time to time shall be forwarded to the Regional Office for their use during monitoring.</p> <p>A complete set of documents including Environmental Impact Assessment (EIA) Report and Environment Management Plan (EMP) along with the additional information/clarifications was already submitted to Regional Office (Western Zone) of the MOEF&CC at Bhopal on 05.10.2015</p>

<p align="center">KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i></p>		
xviii	The details of the funds along with item-wise break-up of Rs.1421.2 crores allocated for implementation of environmental protection measures shall be submitted to the Ministry. This cost shall be included as part of the project cost. The funds earmarked for the environment protection measures shall not be diverted for other purposes and year-wise expenditure shall be reported to the Ministry.	The requisite funds for environmental mitigation measures have been included in the project cost. Financial provision stipulated towards environmental mitigate measures shall not be diverted for other purposes.
xix	The project authorities shall inform the Regional Office as well as the Ministry regarding the date of financial closure and final approval of the project by the concerned authorities and the dates of start of land development work and commissioning of plant.	Shall be complied
		Site leveling/ Land development work started on July 17 th , 2015.
		Full load commissioning of Unit#1 (660 MW) achieved on 30.08.2019. COD is declared from 01/2/2020. Full load commissioning of Unit#2 (660 MW) achieved on 19.01.2020. COD is declared from 04/4/2020.
xx	Full cooperation shall be extended to the Scientists/officers from the Ministry / Regional Office of the Ministry/ CPCB /SPCB who would be monitoring the compliance of environmental status.	Full cooperation shall be extended to the Scientists/ Officers from the Ministry/ Regional Office of the Ministry at Bhopal/ CPCB/ SPCB during monitoring of the project.
5	The Ministry reserves the right to revoke the clearance if conditions stipulated are not implemented to the satisfaction. The Ministry may also impose additional environmental conditions or modify the existing ones, if necessary.	Noted.
6	The environmental clearance accorded shall be valid for a period of 5 years from the date of issue of this letter to start operation of the power plant.	Noted.
7	Concealing factual data or submission of false/fabricated data and failure to comply with any of the conditions mentioned above may result in withdrawal of this clearance and attract	Noted.

KHARGONE SUPER THERMAL POWER PROJECT (2X660 MW) COMPLIANCE REPORT OF ENVIRONMENTAL CLEARANCE CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 31st March 2015)</i>		
	action under the provisions of Environment (Protection) Act, 1986.	
8	In case of any deviation or alteration in the project proposed including coal transportation system from those submitted to this Ministry for clearance, a fresh reference should be made to the Ministry to assess the adequacy of the condition(s) imposed and to add additional environmental protection measures required, if any.	Noted.
9	The above stipulations would be enforced among others under the water (prevention and Control of pollution) Act, 1974, the Air (Prevention and Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986 and rules there under, Hazardous Wastes (Management, Handling & Trans-boundary Movement) Rules, 2008 and its amendments, the public Liability Insurance Act, 1991 and its amendments.	Noted.
10	Any appeal against this Environmental Clearance shall lie with the National Green Tribunal, if preferred, within 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.	Noted.

COMPLIANCE REPORT OF ADDITIONAL CONDITIONS <i>(Vide Letter No. J- 13012/54/2010-IA. II (T) Dated 22nd August 2019)</i>		
	MOEF & CC Stipulations	NTPC Response
A	Specific Conditions:	Status as on 30.09.2019
1	While commissioning the proposed project, the compliance of revised emission norms vide Notification dated 07.12.2015 for the parameters PM: 30 mg/Nm ³ ; SO ₂ : 100 mg/Nm ³ ; NO _x : 100 mg/Nm ³ and Hg: 0.03 mg/Nm ³ shall be achieved along with specific water consumption as per the notification vide dated 28.06.2018. The FGD System, NO _x control measures such as SCR/ SCNR/	NTPC Khargone STPP ensures compliance to all standards as stipulated in the revised/latest MOEF&CC emission norms for TPP dated 07.12.2015 and optimize its specific water consumption as per the MOEF&CC notification dated 28.06.2018.

	DeNOx burners shall be installed to achieve the revised emission norms.	
2	The status of installation of FGD and De-NOx/ SCR/ SCNR control systems to comply with new emission norms for both units shall be submitted.	<p>For SOx control, installation of FGD plant package is awarded to M/s L&T in Sep'2018. Erection works are in full swing and shall be completed within 34 months. Status of installation of FGD is enclosed at Annexure-IV</p> <p>For NOx control, air/fuel ratio around the burner shall be optimized to ensure low emission of NOx.</p> <p>Globally available SCR system for reducing NOX emissions are not tested for Indian coal having high ash contents. Pilot test studies are being conducted at NTPC units at different locations to test efficacy of SCR system on Indian coal.</p>
3	The detailed progress report of construction of proposed project shall be submitted to the Ministry and its Regional Office along with six monthly compliance report till the both units are commissioned.	<p>Full load commissioning of Unit#1 (660 MW) achieved on 30.08.2019. COD is declared from 01/2/2020</p> <p>Full load commissioning of Unit#2 (660 MW) achieved on 19.01.2020. COD is declared from 04/4/2020</p>
4	As per the Revised Tariff Policy notified of Ministry of Power issued vide dated 28.01.2016, project proponent shall explore the use of treated sewage water from the Sewage Treatment Plant of Municipality/ local bodies/ similar organization located within 50 km radius of the proposed power project to minimize the water drawl from surface water bodies. The details of Sewage Treatment Plants located within 50 km radius along with the capacities shall be submitted.	<p>As per MP Govt. proposed action plan for rejuvenation of Kunda river at Khargone, presently single sewage treatment plant of very low capacity of 50 KLD is available with municipal corporation of Khargone. Details of proposed action plan enclosed already submitted with 9th HYC report on 02/11/19</p> <p>Use of treated sewage water shall be explored in near future.</p>
5	Daily quantity of (Average, minimum and maximum) fresh water withdrawn from Narmada River at Omkareshwar Dam for the plant purpose shall be submitted along with six monthly compliance report.	Fresh water withdrawn data is enclosed at Annexure-V