



एन टी पी सी लिमिटेड
(भारत सरकार का उद्यम)
NTPC Limited
(A Govt. of India Enterprise)

Ref No: 01/GNI/EC/02

Date: 03.06.2026

To,
Deputy Director General of Forests (C),
Ministry of Environment, Forest and Climate Change,
Integrated Regional Office,
1st floor Additional Office Block for GPOA, Shastri Bhawan,
Haddows Road, Nungambakkam, Chennai -600 006

Ref: EC & CRZ Clearance letter dated 11.11.2022 and Split & Transfer of EC & CRZ Clearance letter dated 18.03.2025

Sub: Online submission of Half-yearly EC Compliance Report for the period 01 October 2025 to 31 March 2026 on PARIVESH portal - reg


Sir,

This has reference to your letter dated 18.03.2025 regarding Split & transfer of Environmental Clearance for the 450 MVA Gas and Solar based power plant at an area of 39 Ha in the name of M/s NTPC Limited from the EC & ICRZ Clearance granted by the Ministry vide letter F.No.10/17/2021-IA-III dated 11.11.2022 for the Integrated Development of International Container Transshipment Terminal (ICTT)-14.2 million TEU, Township & Area Development, and 450 MVA Gas and Solar-based Power Plant in 16,610 ha at Great Nicobar Islands, Nicobar District by M/s Andaman and Nicobar Islands Integrated Development Corporation..

In compliance with EC Standard Condition No. F (iv), we are submitting six -monthly compliance report on PARIVESH portal for the period 01 October 2025 to 31 March 2026 on PARIVESH Portal and through soft copy for your ready reference. We would like to further inform that no construction work has started on ground.

Encl: A/A

Yours faithfully,
For & on behalf of NTPC Limited


03/06/26

(Dharmendra Kumar)
Head of Project (Great Nicobar)
Sri Vijaya Puram, ANI

Copy to:

1. Commissioner cum Secretary (Environment & Forest), A & N Administration.
2. Principal Chief Conservator of Forest (PCCF), Department of Environment & Forests, Van Sadan, Haddo, Sri Vijaya Puram, A&N Islands.
3. Member Secretary, Andaman and Nicobar Coastal Zone Management Authority, Van Sadan, Haddo, Sri Vijaya Puram, A & N Islands.

पंजीकृत ऑफिस : एनटीपीसी भवन, स्कोप कॉम्प्लेक्स, 7, इंस्टीट्यूशनल एरिया, लोधी रोड, नई दिल्ली-110003
सीआईएन : L40101DL1975GOI007966 | टेलीफोन : 011-24387333 | फैक्स : 011-24361018 | ntpccc@ntpc.co.in | www.ntpc.co.in
Registered Office : NTPC Bhawan, SCOPE Complex, 7, Institutional Area, Lodi Road, New Delhi-110003
CIN : L40101DL1975GOI007966 | Tel : 011-24387333 | Fax : 011-24361018 | ntpccc@ntpc.co.in | www.ntpc.co.in



एनटीपीसी लिमिटेड
(भारत सरकार का उद्यम)
NTPC Limited
(A Govt. of India Enterprise)

4. Member secretary, Andaman & Nicobar Islands Pollution Control Committee (ANIPCC), Department of Science and Technology, Dollygunj, Sri Vijaya Puram, A & N Islands.
5. Addl. Principal Chief Conservator of Forests (C), MoEF&CC (SEZ), 1st floor Additional Office Block for GPOA, Shastri Bhawan, Haddows Road, Nungambakkam, Chennai -600 006.
6. Deputy Director General of Forest, Integrated Regional office, MoEF&CC, IB-198, Sector -III, Salt Lake City, Kolkata -700106.
7. The Secretary, Ministry of Port, Shipping & Waterways, Parivahan Bhavan, 1, Parliament Street, New Delhi.
8. The Secretary, Ministry of Power, Shram Shakti Bhawan, Rafi Marg, New Delhi -110003.
9. Deputy Secretary (UT), Ministry of Home Affairs (MHA), Govt. of India, North Block, New Delhi-110001.
10. Monitoring Cell, MoEF&CC, Indira Paryavaran Bhavan, New Delhi.

पंजीकृत ऑफिस : एनटीपीसी भवन, स्कोप कॉम्प्लेक्स, 7, इंस्टीट्यूशनल एरिया, लोधी रोड, नई दिल्ली-110003
सीआईएन : L40101DL1975GOI007966 | टेलीफोन : 011-24387333 | फैक्स : 011-24361018 | ntpccc@ntpc.co.in | www.ntpc.co.in
Registered Office : NTPC Bhawan, SCOPE Complex, 7, Institutional Area, Lodi Road, New Delhi-110003
CIN : L40101DL1975GOI007966 | Tel : 011-24387333 | Fax : 011-24361018 | ntpccc@ntpc.co.in | www.ntpc.co.in

Half Yearly Compliance Report**2026****01 Jun(01 Oct - 31 Mar)****Acknowledgement**

Proposal Name	Split and transfer of Environment Clearance for the 450 MVA Gas and Solar based power plant at an area of 39 Ha in the name of M/s NTPC Limited from the EC and ICRZ Clearance granted to M/s Andaman and Nicobar Islands Integrated Development Corporation		
Name of Entity / Corporate Office	NTPC Limited		
Village(s)	N/A		
District	NICOBARS		
Proposal No.	IA/AN/INFRA1/517388/2025	Category	INFRA-1
Plot / Survey / Khasra No.	N/A	Sub-District	N/A
State	ANDAMAN AND NICOBAR ISLANDS	Entity's PAN	*****0255D
MoEF File No.	10/17/2021-IA-III	Entity name as per PAN	NTPC LIMITED

Compliance Reporting Details

Reporting Year	2026
Remarks (if any)	Six Monthly Compliance Report of Environmental Clearance Period: 01.10.2025 to 31.03.2026 Land not in possession. As of current date, no construction activity commenced on ground. EC conditions applicable to NTPC is agreed to comply
Reporting Period	01 Jun(01 Oct - 31 Mar)

Details of Production and Project Area

Name of Entity / Corporate Office	NTPC Limited	
	Project Area as per EC Granted	Actual Project Area in Possession
Private	0	0
Revenue Land	0	0
Forest	39	39
Others	N/A	N/A
Total	39	39

Others Area

Sr. no	Other Name	Area Granted	Area Actual			
Production Capacity						
Sr. no	Product Name	units	Valid Upto	Capacity	Production last year	Capacity as per CTO
1	Gas and Solar based Power Plant	Others:MVA	N/A	450	0	
Conditions						
Specific Conditions						
Sr.No.	Condition Type	Condition Details				
1	Statutory compliance	XLII. The recommendation from Standing Committee of NBWL under the Wildlife (Protection) Act, 1972 should be obtained, if applicable.				
PPs Submission: Agreed to Comply Noted and compliance will be ensured.					Date: 03/06/2026	
2	WATER QUALITY MONITORING AND PRESERVATION	VIII. No withdrawal of water from Galathea River is permitted. Galathea River must remain free of any recreational activity. No ground withdrawal of freshwater will be permitted. Drinking water will be exclusively augmented through two reservoirs proposed along with capacity augmentation of existing freshwater storage facilities at GNI.				
PPs Submission: Agreed to Comply Noted and compliance will be ensured.					Date: 03/06/2026	
3	MISCELLANEOUS	IX. Construction activity shall be carried out strictly according to the provisions of the ICRZ Notification, 2019. No construction works other than those permitted in Coastal Regulation Zone Notification shall be carried out in Coastal Regulation Zone area				
PPs Submission: Agreed to Comply Noted and compliance will be ensured.					Date: 03/06/2026	
4	MISCELLANEOUS	X. All the recommendations and conditions specified by the Andaman Nicobar Coastal Zone Management Authority (ANCZMA) vide letter dated 8th July 2022 shall be complied with.				
PPs Submission: Agreed to Comply Noted and compliance will be ensured.					Date: 03/06/2026	
5	Statutory compliance	XI. Consent to Establish/Operate for the project shall be obtained from the State Pollution Control Board as required under the Air (Prevention and Control of Pollution) Act, 1981 and the Water (Prevention and Control of Pollution) Act, 1974. The project proponent shall comply with the air pollution mitigation measures as submitted.				

PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
6	WATER QUALITY MONITORING AND PRESERVATION	XII. The Project proponent shall ensure that no creeks or rivers are blocked due to any activities at the project site and free flow of water is maintained.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
7	WASTE MANAGEMENT	XIII. Necessary approvals to be taken during implementation and commissioning from statutory bodies concerned.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
8	MISCELLANEOUS	XIV. Shoreline should not be disturbed due to dumping. Periodical study on shoreline changes and coastal geomorphology shall be conducted and mitigation measures like living shoreline carried out in line with conservation plan. The details shall be submitted along with the six-monthly monitoring report to the regional office of MoEF and CC.
PPs Submission: Agreed to Comply Not Applicable as project not located at shoreline		Date: 03/06/2026
9	GREENBELT	XV. No trees will be cut at one go. These will be done in phased manner and depend on the progress of the work on an annual basis. Plan for cutting trees should be developed by PP and got approved from state forest department. All trees which are exceptionally tall and old in age shall be safeguarded, as far as possible. AandNFD will mark all such trees and submit the species wise list to the Ministry and EAC and the regional office of MoEFandCC before the infrastructure activities take place
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
10	GREENBELT	XVI. Trees with nesting holes of endemic owls to be identified and geo - tagged with the help from SACON. Such trees shall be safeguarded, as far as possible.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
11	MISCELLANEOUS	XXIII. All illumination for ICTT, Gas-based power plant and other infrastructure adjacent to sea turtle nesting areas must be in conformity with international standards and sea turtle friendly. No other type of illumination would be permitted. WII will develop illumination policy for the entire infrastructure and PP will ensure its implementation.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
12	ENERGY PRESERVATION	XXVII. PP must explore and use non- conventional sources of

	MEASURES	energy in the form of solar, wind or tidal energy to bridge the deficit, if needed.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
13	AIR QUALITY MONITORING AND PRESERVATION	XXXI. Optimum number (minimum 2) of roadside monitors (CAAQMS) at appropriate distance from the kerb of the road shall be fixed following the CPCB criteria to monitor biogenic VOCs, NO _x and PM _{2.5} .
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
14	WASTE MANAGEMENT	XXXII. Disposal of hazardous waste material would not be allowed in GNI including batteries, pesticides, organochlorines etc.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
15	WASTE MANAGEMENT	XXXIII. The waste generated during construction and operation period of the project shall be managed as per the prevailing regulations on management of solid waste, plastic waste, e- waste, bio-medical waste, CandD waste and hazardous wastes issued in 2016 by the Ministry. The waste shall be segregated and should be recycled/reused as per the regulatory provisions. No Municipal Landfills will be allowed in GNI. All rejects after the recycling/reuse of waste must be transported to mainland for its safe disposal. A separate application for TSDF shall be made to the Ministry in case of establishment of TSDF at GNI.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
16	ENERGY PRESERVATION MEASURES	XXXIV. For the first 5 years (Phase I) of the project, power demand shall be met through Diesel Generators (DG). Phase I of project shall include construction and commissioning of 50MVA gas-based power plant and floating solar power plant in water reservoirs. The combined installed capacity to 90 MVA through diesel and gas-based power will further be augmented by 20 MVA through first phase of solar power from 6th year. During 10-15 years (Phase II), the power generation shall be augmented to 220 MVA by increasing the installed capacity of Gas based power plant to 150 MVA and increasing the Solar power generation by additional 50 MVA taking total Solar power generation to 70 MVA. During 15 to 30 years (Phase III) the Gas based power plant capacity shall be increased to 300 MVA and Solar power plant shall be augmented to 100 MVA.
PPs Submission: Agreed to Comply 1. NTPC installed capacity in 1st phase (108 MW) LNG Power Plant has been finalized to meet the simultaneous peak demand as communicated by respective stakeholders under Great Nicobar Holistic Development program. 2. The 17.66 MWac (Based on Area of 75 acre provided in reservoir by ANIIDCO) floating solar plant will be taken up for implementation upon completion of the reservoir works (under ANIIDCOs scope) and handover of the required water surface area/front to NTPC by ANIIDCO.		Date: 03/06/2026
17	Risk Mitigation and Disaster Management	XXXVI. All the facilities such as port, powerplant and township etc., to be designed to withstand seismic and Tsunami hazard and

		detailed plan should be submitted to monitoring committee.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
General Conditions		
Sr.No.	Condition Type	Condition Details
1	Statutory compliance	C. 450MVA Gas and Solar based power plant: I. Statutory Compliance: i. Part C of Schedule II of Municipal Solid Wastes Rules, 2016 dated 08.04.2016 as amended from time to time shall be complied for power plants based on Municipal Solid Waste. ii. The recommendation from Standing Committee of NBWL under the Wildlife (Protection) Act, 1972 should be obtained, if applicable. iii. No Objection Certificate from Ministry of Civil Aviation be obtained for installation of requisite chimney height and its siting criteria for height clearance. iv. Groundwater shall not be drawn during construction of the project. In case, groundwater is drawn during construction, necessary permission be obtained from CGWA.
PPs Submission: Agreed to Comply i Not applicable ii. Noted and compliance will be ensured. iii. Noted and compliance will be ensured. iv. Noted and compliance will be ensured.		Date: 03/06/2026
2	AIR QUALITY MONITORING AND PRESERVATION	C. 450MVA Gas and Solar based power plant: II. Air quality monitoring and Management: i. Stacks of prescribed height shall be provided with continuous online monitoring instruments for SOX, NOx and Particulate Matter as per extant rules. ii. Exit velocity of flue gases shall not be less than 20-25 m/s. Mercury emissions from stack shall also be monitored periodically. iii. Continuous Ambient Air Quality monitoring system shall be set up to monitor common/criteria pollutants from the flue gases such as PM10, PM2.5, SO2, NOX within the plant area at least at one location. The monitoring of other locations (at least three locations outside the plant area covering upwind and downwind directions at an angle of 120 degree each) shall be carried out manually. iv. Appropriate Air Pollution Control measures (DEs/DSs) be provided at all the dust generating sources including sufficient water sprinkling arrangements at various locations viz., roads, excavation sites, crusher plants, transfer points, loading and unloading areas, etc.
PPs Submission: Agreed to Comply i. Noted and compliance will be ensured ii. Noted and this will be complied once the project is commissioned. iii. Noted and this will be compiled once the project is erection is started. A third party Agency will be hired for this work during the erection and commissioning phase of the project. iv: During the construction phase manual water sprinkling will be ensured to suppress the dust.		Date: 03/06/2026
3	Noise Monitoring & Prevention	C. 450 MVA Gas and Solar based power plant: III. Noise pollution and its control measures: i. The Ambient Noise levels shall meet the standards prescribed as per the Noise Pollution (Regulation and Control) Rules, 2000. ii. Persons exposed to high noise generating equipment shall use Personal Protective Equipment (PPE) like earplugs/ear muffs, etc. iii. Periodical medical examination on hearing loss shall be carried out for all the workers and maintain audiometric record and for treatment of any hearing loss including rotating to non-noisy/less noisy areas

<p>PPs Submission: Agreed to Comply i. Noted and compliance will be ensured. ii. Noted and compliance will be ensured. iii. Noted and compliance will be ensured.</p>		<p>Date: 03/06/2026</p>
4	Human Health Environment	<p>C. 450 MVA Gas and Solar based power plant: IV Human Health Environment: i. Bi-annual Health check-up of all the workers is to be conducted. The study shall take into account of chronic exposure to noise which may lead to adverse effects like increase in heart rate and blood pressure, hypertension and peripheral vasoconstriction and thus increased peripheral vascular resistance. Similarly, the study shall also assess the health impacts due to air polluting agents. ii. Baseline health status within study area shall be assessed and report be prepared. Mitigation measures should be taken to address the endemic diseases. iii. Impact of operation of power plant on agricultural crops, large water bodies (as applicable) once in two years by engaging an institute of repute. The study shall also include impact due to heavy metals associated with emission from power plant. iv. Sewage Treatment Plant shall be provided for domestic wastewater.</p>
<p>PPs Submission: Agreed to Comply i. Noted and compliance will be ensured. ii. Noted and compliance will be ensured. iii. Noted and compliance will be ensured. iv. Noted and compliance will be ensured.</p>		<p>Date: 03/06/2026</p>
5	Risk Mitigation and Disaster Management	<p>C. 450 MVA Gas and Solar based power plant: V. Risk Mitigation and Disaster Management: i. Storage facilities for auxiliary liquid fuel such as LDO and HFO/LSHS shall be made as per the extant rules in the plant area in accordance with the directives of Petroleum and Explosives Safety Organisation (PESO). Sulphur Content in the liquid fuel should not exceed 0.5 percentage. ii. Ergonomic working conditions with First Aid and sanitation arrangements shall be made for the drivers and other contract workers during construction phase. iii. Safety management plan based on Risk Assessment shall be prepared to limit the risk exposure to the workers within the plant boundary. iv. Regular mock drills for on-site emergency management plan and Integrated Emergency Response System shall be developed for all kind of possible disaster situations.</p>
<p>PPs Submission: Agreed to Comply i. Noted and compliance will be ensured. ii. Noted and compliance will be ensured during construction phase. iii. Noted and compliance will be ensured. iv. Noted and compliance will be ensured.</p>		<p>Date: 03/06/2026</p>
6	Human Health Environment	<p>D Public hearing and human health issues: (i) The work space shall be maintained as per international standards for occupational health and safety with provision of fresh air respirators, blowers, and fans to prevent any accumulation and inhalation of undesirable levels of pollutants including VOCs. (ii) Workers shall be strictly enforced to wear personal protective equipments like dust mask, ear muffs or ear plugs, whenever and wherever necessary/ required. Special visco elastic gloves will be used by labour exposed to hazards from vibration. (iii) In case of repair of any old vessels, excessive care shall be taken while handling Asbestos and Freon gas. Besides, fully enclosed covering should be provided for the temporary storage of asbestos materials at site before disposal to CTSD. (iv) Safety training shall be given to all workers specific to their work area and every worker and employee will be engaged in fire hazard awareness training and mock drills which will be conducted regularly. All standard safety and occupational hazard measures shall be implemented and monitored by the concerned officials to prevent the occurrence of untoward incidents/ accidents. (v) Emergency</p>

		preparedness plan based on the Hazard identification and Risk Assessment (HIRA) and Disaster Management Plan shall be implemented. (vi) Provision shall be made for the housing of construction labour within the site with all necessary infrastructure and facilities such as fuel for cooking, mobile toilets, mobile STP, safe drinking water, medical health care, creche etc. The housing may be in the form of temporary structures to be removed after the completion of the project. (vii) Occupational health surveillance of the workers shall be done on a regular basis.
PPs Submission: Agreed to Comply i. Noted and compliance will be ensured. ii. Noted and compliance will be ensured. iii. Noted and compliance will be ensured. iv. Noted and compliance will be ensured.		Date: 03/06/2026
7	MISCELLANEOUS	E. Environment Responsibility: (i) The company shall have a well laid down environmental policy duly approved by the Board of Directors. The environmental policy should prescribe for standard operating procedures to have proper checks and balances and to bring into focus any infringements/deviation/violation of the environmental / forest /wildlife norms/ conditions. The company shall have defined system of reporting infringements / deviation / violation of the environmental / forest / wildlife norms / conditions and / or shareholders / stake holders. The copy of the board resolution in this regard shall be submitted to the MoEFCC as a part of six-monthly report. (ii) Action plan for implementing EMP and environmental conditions along with responsibility matrix of the company shall be prepared and shall be duly approved by competent authority. The year wise funds earmarked for environmental protection measures shall be kept in separate account and not to be diverted for any other purpose. Year wise progress of implementation of action plan shall be reported to the Ministry/Regional Office along with the Six Monthly Compliance Report. (iii) Self environmental audit shall be conducted annually. Every three years third party environmental audit shall be carried out.
PPs Submission: Agreed to Comply i. Noted and compliance will be ensured. ii. Noted and compliance will be ensured. iii. Noted and compliance will be ensured.		Date: 03/06/2026
8	MISCELLANEOUS	F. Miscellaneous - (i)The project proponent shall make public the environmental clearance granted for their project along with the environmental conditions and safeguards at their cost by prominently advertising it at least in two local newspapers of the District or State, of which one shall be in the vernacular language within seven days and in addition this shall also be displayed in the project proponent website permanently.
PPs Submission: Complied C was already published by ANIIDCO in two newspapers on 12.09.2022. After Splitting and transfer of EC of Power Project from ANIIDCO to NTPC Ltd and it was published in two newspapers on 06.07.2025. Hindi Newspaper- Andaman Nicobar Dweep Samachar. English Newspaper The Daily Telegrams (Copy of Public Notice is attached) In addition to this, it is also displayed on NTPC website permanently.		Date: 04/06/2026
9	MISCELLANEOUS	F. Miscellaneous- (ii) The copies of the environmental clearance shall be submitted by the project proponents to the Heads of local bodies, Panchayats and Municipal Bodies in addition to the relevant offices of the Government who in turn has to display the same for 30 days from the date of receipt.

PPs Submission: Complied It was submitted vide letter dated 04.07.2025 to local bodies (Copy of submissions are attached).		Date: 04/06/2026
10	MISCELLANEOUS	F. Miscellaneous- (iii) The project proponent shall upload the status of compliance of the stipulated environment clearance conditions, including results of monitored data on their website and update the same on half-yearly basis
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
11	MISCELLANEOUS	F. Miscellaneous- (iv) The project proponent shall submit six monthly reports on the status of the compliance of the stipulated environmental conditions on the website of the ministry of Environment, Forest and Climate Change at environment clearance portal
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
12	MISCELLANEOUS	F. Miscellaneous- (v).The project proponent shall submit the environmental statement for each financial year in Form-V to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently and put on the website of the company
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
13	MISCELLANEOUS	F. Miscellaneous- (vI).The criteria pollutant levels namely; PM2.5, PM10, SO2, NOx (ambient levels) or critical sectoral parameters, indicated for the project shall be monitored and displayed at a convenient location near the main gate of the company in the public domain.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
14	MISCELLANEOUS	F. Miscellaneous- (vii) The project proponent shall inform the Regional Office as well as the Ministry, the date of financial closure and final approval of the project by the concerned authorities, commencing the land development work and start of production operation by the project
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
15	MISCELLANEOUS	F. Miscellaneous- (viii). The project authorities must strictly adhere to the stipulations made by the State Pollution Control Board and the State Government
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
16	MISCELLANEOUS	F. Miscellaneous- (ix). The project proponent shall abide by all the commitments and recommendations made in the EIA/EMP report,

		commitment made during Public Hearing and also that during their presentation to the Expert Appraisal Committee
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
17	MISCELLANEOUS	F. Miscellaneous- (x) No further expansion or modifications in the project shall be carried out without prior approval of the Ministry of Environment, Forests and Climate Change (MoEFandCC)
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
18	MISCELLANEOUS	F. Miscellaneous- (xi). Concealing factual data or submission of false/fabricated data may result in revocation of this environmental clearance and attract action under the provisions of Environment (Protection) Act, 1986
PPs Submission: Agreed to Comply Noted		Date: 03/06/2026
19	MISCELLANEOUS	F. Miscellaneous- (xii). The Ministry may revoke or suspend the clearance, if implementation of any of the above conditions is not satisfactory under the provisions of the Environmental (Protection) Act, 1986, to ensure effective implementation of the suggested safeguard measures in a time bound and satisfactory manner
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
20	MISCELLANEOUS	F. Miscellaneous- (xiii).The Ministry reserves the right to stipulate additional conditions if found necessary. The Company in a time bound manner shall implement these conditions.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
21	MISCELLANEOUS	F. Miscellaneous- (xiv). The Regional Office of this Ministry shall monitor compliance of the stipulated conditions. The project authorities should extend full cooperation to the officer (s) of the Regional Office by furnishing the requisite data / information/monitoring reports.
PPs Submission: Agreed to Comply Noted and compliance will be ensured.		Date: 03/06/2026
22	MISCELLANEOUS	F. Miscellaneous- (xv). The above conditions shall be enforced, inter-alia under the provisions of the Water(Prevention and Control of Pollution) Act, 1974, the Air (Prevention and Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986, Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 and the Public Liability Insurance Act, 1991 along with their amendments and Rules and any other orders passed by the Hon'ble Supreme Court of India / High Courts and any other Court of Law relating to the subject matter.

PPs Submission: Agreed to Comply
Noted and compliance will be ensured.

Date:
03/06/2026

23

MISCELLANEOUS

F. Miscellaneous- (xvi). Any appeal against this EC shall lie with the National Green Tribunal, if preferred, within a period of 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.

PPs Submission: Agreed to Comply
Noted

Date:
03/06/2026

Visit Remarks

Last Site Visit Report Date:

N/A

Additional Remarks:

As of current date, no construction activity commenced on ground.

Note: This acknowledgement is as per the details submitted by project proponent. In no way is this document to be considered as conclusion on any action on the compliance of the project. This is strictly for the project proponent's reference purpose.